



012

CERTIFICATE OF REGISTRATION

This is to certify that the Building Insulation Product known as

TRISO SUPER 10+

manufactured by

ACTIS SA
30 Avenue de Catalogne
11300 Limoux
France

and distributed in the UK by

ACTIS INSULATION Ltd
Unit 2a Cornbrash Park, Bumpers Way
Bumpers Farm Industrial Estate
Chippenham
Wiltshire
SN14 6RA

has been assessed in accordance with the BM TRADA Building Insulation Products Scheme, including in-situ testing in accordance with TRADA Technology Ltd test protocol BIP-001, for use in roof construction and has an in-situ thermal insulation performance equivalent to 210mm of mineral wool. *TRISO SUPER 10+ is registered within the BM TRADA Certification Scheme for

Building Insulation Products

*The mineral wool used to establish equivalence conforms to EN 13162, has a declared thermal conductivity of 0.04W/mK and 210mm of this mineral wool has a declared R value of 5.25m²K/W. The thermal performance equivalence is between the two tested roof structures, and includes all the associated heat losses, such as thermal properties of the materials, air leakage and thermal bridging, the structures being designed with realistic and identical air tightness and fractional timber surface area to ensure that the results of the test are representative of commonly used roof structures.

The validity of this certificate is dependent on the adherence to the conditions laid down in the accompanying Q-Mark Schedule. The Q-Mark Schedule is an integral part of this certificate.

As a Scheme member the Company agrees to maintain the fabrication and design of its TRISO SUPER 10+ product in accordance with the BM TRADA Scheme requirements and to use the Q-Mark in accordance with the Scheme Requirements.

Certificate Number

BIPS-0106

Date of Initial Certification

25 October 2011

Date of Last Issue

21 April 2020

Date of Expiry

23 October 2021

Karen Prendergast
Divisional Director - Certification
BM TRADA

Warringtonfire Testing and Certification Limited t/a BM TRADA, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND, UK
Registered Office: Warringtonfire Testing and Certification Limited, 10 Lower Grosvenor Place, London, SW1W 0EN, UK.
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com